



Notice to Respondents

Contract Number: Q2019-21

Notice Number

001

Date

12/09/2019

Project Name

Design and Construction
of Dajarra Amenities Block
Sewer Connection

Authorised by

Name/Position

Signature

Date

Charles Taylor

12/09/2019

Details of Notice to Respondents

The following questions have been received:

1. Is a 240v power available to connect to?

The power supply in Dajarra is single SWER line.

ENDORSEMENT

To be submitted with tender. It is agreed that my tender price is based on Notice to Respondents No. 1 to the tender documents.

Name of Respondent: _____

Signature of Respondent:

Date: _____